

SPRINKLER SYSTEM DESIGN CRITERIA:

- THE EXISTING BUILDING IS FULLY PROTECTED WITH AN AUTOMATIC WET SPRINKLER SYSTEM IN ACCORDANCE WITH NFPA-13.
- THE FIRE PROTECTION CONTRACTOR SHALL DESIGN THE MODIFICATIONS TO THE EXISTING AUTOMATIC WET SPRINKLER SYSTEM FOR THE PROJECT AREA IN ACCORDANCE WITH NFPA-13.
- THE MINIMUM DESIGN DENSITY SHALL BE 0.10 GPM PER SQUARE FOOT FOR THE HYDRAULICALLY MOST REMOTE 1,500 SQUARE FEET, LIGHT HAZARD AS DEFINED BY NFPA-13. AREAS OTHER THAN LIGHT HAZARD ARE INDICATED ON THE FLOOR PLANS.
- SPRINKLER LOCATIONS ARE SHOWN TO INDICATE PREFERRED LOCATIONS. THE FIRE PROTECTION CONTRACTOR SHALL BE RESPONSIBLE FOR LOCATING THE SPRINKLERS IN ACCORDANCE WITH NFPA-13 AND THE LOCAL INSPECTIONS DEPARTMENT. SPRINKLERS SHALL BE LOCATED IN THE CENTER OF CEILING TILES.
- THE SCOPE OF WORK INCLUDES REPLACING SPRINKLERS AS REQUIRED TO ACCOMMODATE NEW CEILINGS. HYDRAULIC CALCULATIONS ARE NOT REQUIRED.
- ALL NEW SPRINKLER PIPING SHALL BE SCHEDULE 40 STEEL WITH SCREW FITTINGS. USE 1" ARMOR TO CONNECT SPRINKLERS.
- FLEXIBLE CONNECTIONS ARE NOT ACCEPTABLE.
- ALL NEW SPRINKLERS SHALL MATCH EXISTING.
- ALL SPRINKLER HEAD TEMPERATURE RATINGS SHALL BE ORDINARY (165°F) UNLESS OTHERWISE INDICATED. ALL SPRINKLERS INSTALLED IN GYPSUM, PLASTER AND WOOD CEILINGS SHALL BE CONCEALED TYPE. ALL SPRINKLERS IN ACoustICAL, GYPSUM, AND/OR CORK CEILING SHALL BE SEMI-RECESSED TYPE.
- FIRE CAULK AND SLEEVE ALL PENETRATIONS THROUGH FIRE RATED ASSEMBLIES. REFER TO LIFE SAFETY PLANS FOR RATED ASSEMBLY LOCATIONS.
- ALL LOW POINTS OF THE SPRINKLER SYSTEM SHALL BE PROVIDED WITH DRAINS PER NFPA-13, 2013 EDITION. LOW POINT DRAINS SHALL BE CLEARLY MARKED AND PIPED TO THE EXTERIOR OF THE BUILDING. A VALVE DRAWING SHALL BE PROVIDED IN MECHANICAL ROOM SHOWING THE LOCATIONS OF ALL LOW POINT DRAINS.
- REVIEW ALL ARCHITECTURAL DRAWINGS, INCLUDING ALL REFLECTED CEILING PLANS PRIOR TO PREPARING THE BID.

FIRE PROTECTION LEGEND

PIPING SYMBOLS

SYMBOL	DESCRIPTION
	SPRINKLER LINE

COMPONENTS AND SPECIALTIES

SYMBOL	DESCRIPTION
	SPRINKLER

GENERAL SYMBOLS

PIPING SYMBOLS

SYMBOL	DESCRIPTION
	PIPE DROP
	PIPE RISE
	PIPE CAP
	BRANCH TAKE OFF
	PIPE DROP TEE
	PIPE RISE TEE

LINETYPE SYMBOLS

DESIGNATION	DESCRIPTION
	DEMOLITION WORK (SHOWN ON DEMOLITION PLANS)
	EXISTING WORK
	NEW WORK

REFERENCE SYMBOLS

DESIGNATION	DESCRIPTION
	NORTH ARROW
	POINT OF CONNECTION TO EXISTING
	POINT OF DISCONNECTION

TEXT SYMBOLS

SYMBOL	DESCRIPTION
&	AND
@	AT
°	DEGREE(S) FAHRENHEIT
°C	DEGREE(S) CELSIUS
Ø	DIAMETER, PHASE
/	DIVIDE BY, PER
\$	DOLLAR
=	EQUALS, EQUAL TO
Ø	DIAMETER
DIR	DEIONIZED WATER RETURN
DIS	DEIONIZED WATER SUPPLY
DL	DOOR LOUVER
DN	DOWN
DSP	DRY SPRINKLER PIPE
DTR	DUAL TEMPERATURE RETURN
DTIS	DUAL TEMPERATURE SUPPLY
DW	DISTILLED WATER
EA	EXHAUST AIR
EAT	ENTERING AIR TEMPERATURE
ED	EQUIPMENT DRAIN
EJ	EXPANSION JOINT
ELEV	ELEVATION
EMS	ENERGY MANAGEMENT SYSTEM
EQ	EQUIPMENT, EQUALIZING
ESP	EXTERNAL STATIC PRESSURE
ETC	ETCETERA
EVC	GAS EVACUATION
EWT	ENTERING WATER TEMPERATURE
EX	EXISTING
#FOR	NUMBER 2 FUEL OIL RETURN
#FOS	NUMBER 2 FUEL OIL SUPPLY
#FOR	NUMBER 6 FUEL OIL RETURN
#FOS	NUMBER 6 FUEL OIL SUPPLY
F	FIRE LINE
F&T	FLOAT AND THERMOSTATIC TRAP
FC	FLEXIBLE CONNECTION
FD	FIRE DAMPER, FOUNDATION DRAIN
FDR	FLOOR DRAIN
FDV	FIRE DEPARTMENT VALVE
FF	FINISHED FLOOR
FFE	FINISHED FLOOR ELEVATION
FMFT	FINS PER FOOT
FMINCH	FINS PER INCH
FM	FLOWMETER
FMF	FLOWMETER FITTING
FO	FUEL OIL
FOF	FUEL OIL FILL
FOO	FUEL OIL OVERFLOW
FOR	FUEL OIL RETURN
FOS	FUEL OIL SUPPLY
FOSUCT	FUEL OIL SUCTION
FOT	FUEL OIL TRANSFER
FOTP	FUEL OIL TRANSFER PUMP
FQV	FUEL OIL VENT
FFM	FEET PER MINUTE
FPS	FEET PER SECOND
FS	FLOW SWITCH
FT	FOOT, FEET
FW	FEED WATER
FWR	FEED WATER RECIRCULATION
FWS	FEED WATER SUCTION
F	DEGREE(S) FAHRENHEIT
G	NATURAL GAS
GAL	GALLON, GALLONS
GEN	GENERATOR
GHR	GLYCOL HEATING RETURN
GHS	GLYCOL HEATING SUPPLY
GPH	GALLONS PER HOUR
GPM	GALLONS PER MINUTE
GR	AUTOMOTIVE LUBRICATION PIPING
H	HIGH
HB	HOSE BIB
HED	HOSE END DRAIN VALVE
HP	HORSEPOWER
HPR	HIGH PRESSURE STEAM RETURN
HPS	HIGH PRESSURE STEAM SUPPLY
HR	HEATING WATER RETURN
HRR	HEAT RECOVERY RETURN
HRS	HEAT RECOVERY SUPPLY
HRSG	HEAT RECOVERY STEAM GENERATOR
HS	HEATING WATER SUPPLY
HT	HEIGHT
HTHR	HIGH TEMPERATURE HEATING WATER RETURN

GENERAL ABBREVIATIONS

#	NUMBER, POUND	HTHS	HOT WATER
\$	DOLLAR	HW	HOT WATER RETURN
%	PERCENT	HWR	HEATING WATER SUPPLY
&	AND	HWR	HEATING WATER RETURN
+	PLUS	HWS	HEATING WATER SUPPLY
-	MINUS	HZ	HERTZ
/	DIVIDE BY, PER	IA	INSTRUMENT AIR
<	LESS THAN	ICW	INDUSTRIAL COLD WATER
=	EQUALS, EQUAL TO	IHR	INDUSTRIAL HOT WATER RECIRCULATION
>	GREATER THAN	IHW	INDUSTRIAL HOT WATER
x	MULTIPLY BY, BY	IN	INCH, INCHES
x'	INCHES, INCH	INV EL	INVERT ELEVATION
x"	FEET, FOOT	KW	KILOWATTS
±	PLUS OR MINUS	L	LONG LENGTH
±	LESS THAN OR EQUAL TO	LA	LABORATORY AIR
≥	GREATER THAN OR EQUAL TO	LAT	LEAVING AIR TEMPERATURE
@	AT	LBS	POUNDS
A	COMPRESSED AIR	LBSHR	POUNDS PER HOUR
AAV	AUTOMATIC AIR VENT	LN	LIQUID NITROGEN
ACV	AUTOMATIC CONTROL VALVE	LP	LIQUID PROPANE
AD	ACCESS DOOR, AREA DRAIN	LPG	LIQUID PETROLEUM GAS
AF	ANTIFREEZE	LPR	LOW PRESSURE STEAM RETURN
AFB	ABOVE FINISHED FLOOR	LPS	LOW PRESSURE STEAM SUPPLY
ARG	ARGON GAS	LV	LABORATORY VENT, LABORATORY VACUUM
ATC	AUTOMATIC TEMPERATURE CONTROL	LW	LABORATORY WASTE
BAS	BUILDING AUTOMATION SYSTEM	LWT	LEAVING WATER TEMPERATURE
BBD	BOILER BLOWDOWN	MA	MEDICAL AIR
BCWR	BEARING COOLING WATER RETURN	MAV	MANUAL AIR VENT
BCWS	BEARING COOLING WATER SUPPLY	MAX	MAXIMUM
BDD	BACKDRAFT DAMPER	MBH	MOTOR CONTROL CENTER
BFP	BACKFLOW PREVENTER	MEQ	MOTOR OPERATED DAMPER
BHP	BRAKE HORSEPOWER	MFM	MEDIUM PRESSURE STEAM RETURN
BMS	BUILDING MANAGEMENT SYSTEM	MFS	MEDIUM PRESSURE STEAM SUPPLY
BO	BLOW OFF	MV	MEDICAL VACUUM
BTU	BRITISH THERMAL UNIT	N	NITROGEN
BTUH	BRITISH THERMAL UNIT PER HOUR	NA, N/A	NOT APPLICABLE
BV	BALANCING VALVE	NC	NOISE CRITERIA, NORMALLY CLOSED
CA	CONTROL AIR	NFA	NATIONAL FIRE PROTECTION ASSOCIATION
CB	CONTINUOUS BLOWDOWN	NG	NATURAL GAS
CC	CAMPUS CONDENSATE	NO	NORMALLY OPEN, NITROUS OXIDE
CCMS	CENTRAL CONTROL AND MONITORING SYSTEM	N#	NUMBER
CD	CONDENSATE DRAIN	NOM	NOMINAL
CF	CHEMICAL FEED	NPSH	NET POSITIVE SUCTION HEAD
CFM	CUBIC FEET PER MINUTE	NPW	NON-POTABLE WATER
CHEL	CHELANT	O	OXYGEN
CHR	CHILLED WATER RETURN	OA	OUTSIDE AIR
CHS	CHILLED WATER SUPPLY	OD	OVERFLOW DRAIN
CHX	CHILLED WATER HEAT EXCHANGER	OED	OPEN ENDED DUCT
CI	CLEANOUT	OF	OVERFLOW
CO2	CARBON DIOXIDE	OSBY	OUTSIDE STEM AND YOKE
CS	CLEAN STEAM	P&ID	PROCESS AND INSTRUMENTATION DIAGRAM
CT	COMBUSTION TURBINE	PA	PLANT AIR
CW	COLD WATER, DOMESTIC CITY WATER	PC	PUMPEE CONDENSATE
CWR	CONDENSER WATER RETURN	PCR	PRIMARY CHILLED WATER RETURN
CWS	CONDENSER WATER SUPPLY	PCHS	PRIMARY CHILLED WATER SUPPLY
°C	DEGREE(S) CELSIUS	PCP	PUMP CONTROL PANEL
D	DEEP, DRAIN WATER	PCR	PUMPEE CONDENSATE RECIRCULATION
DB	DRYBULB, DRY BULB	PCWR	PROCESS COOLING WATER RETURN
DDC	DIRECT DIGITAL CONTROL	PCS	PROCESS COOLING WATER SUPPLY
DESIG	DESIGNATION	PD	PRESSURE DROP, PUMP DISCHARGE
DHR	DISTRIBUTION HEATING WATER RETURN	PG	PILOT GAS
DHS	DISTRIBUTION HEATING WATER SUPPLY	PGR	PROCESS GLYCOL WATER RETURN
DHW	DOMESTIC HOT WATER RETURN	PGS	PROCESS GLYCOL WATER SUPPLY
DHWS	DOMESTIC HOT WATER SUPPLY	PH	PHASE
Ø	DIAMETER	PHR	PRIMARY HEATING RETURN
DIR	DEIONIZED WATER RETURN	PHS	PRIMARY HEATING SUPPLY
DIS	DEIONIZED WATER SUPPLY	PIV	POST INDICATING VALVE
DL	DOOR LOUVER	PHI	POUNDS PER HOUR
DN	DOWN	PRV	PRESSURE REDUCING VALVE, PRESSURE REGULATING
DSP	DRY SPRINKLER PIPE	PSI	POUNDS PER SQUARE INCH
DTR	DUAL TEMPERATURE RETURN	PSIG	POUNDS PER SQUARE INCH GAUGE
DTS	DUAL TEMPERATURE SUPPLY	PW	POTABLE WATER
DW	DISTILLED WATER	RA	RETURN AIR, RELIEF AIR
EA	EXHAUST AIR	RAF	RETURN AIR FAN
EAT	ENTERING AIR TEMPERATURE	RD	REFRIGERANT DISCHARGE
ED	EQUIPMENT DRAIN	RDR	ROOF DRAIN
EJ	EXPANSION JOINT	RH	RELATIVE HUMIDITY
ELEV	ELEVATION	RHR	REHEAT WATER RETURN
EMS	ENERGY MANAGEMENT SYSTEM	RHS	REHEAT WATER SUPPLY
EQ	EQUIPMENT, EQUALIZING	RI	REMOVE AND REINSTALL
ESP	EXTERNAL STATIC PRESSURE	RL	REFRIGERANT LIQUID
ETC	ETCETERA	ROR	REVERSE OSMOSIS WATER RETURN
EVC	GAS EVACUATION	ROS	REVERSE OSMOSIS WATER SUPPLY
EWT	ENTERING WATER TEMPERATURE	RPM	REVOLUTIONS PER MINUTE
EX	EXISTING	RS	REFRIGERANT SUCTION
#FOR	NUMBER 2 FUEL OIL RETURN	RV	RELIEF VENT, REFRIGERANT VENT
#FOS	NUMBER 2 FUEL OIL SUPPLY	RX	REMOVE EXISTING
#FOR	NUMBER 6 FUEL OIL RETURN	SA	SUPPLY AIR
#FOS	NUMBER 6 FUEL OIL SUPPLY	SA	SHOCK ARRESTOR
F	FIRE LINE	SAN	SANITARY, SOIL, WASTE
F&T	FLOAT AND THERMOSTATIC TRAP	SCHR	SECONDARY CHILLED WATER RETURN
FC	FLEXIBLE CONNECTION	SCHS	SECONDARY CHILLED WATER SUPPLY
FD	FIRE DAMPER, FOUNDATION DRAIN	SD	STORM DRAIN, SMOKE DETECTOR
FDR	FLOOR DRAIN	SF	SQUARE FOOT
FDV	FIRE DEPARTMENT VALVE	SHR	SECONDARY HEATING WATER RETURN
FF	FINISHED FLOOR	SWS	SECONDARY HEATING WATER SUPPLY
FFE	FINISHED FLOOR ELEVATION	SL	SOUND LINING
FMFT	FINS PER FOOT	SP	STATIC PRESSURE
FMINCH	FINS PER INCH	SPR	SPRINKLER LINE
FM	FLOWMETER	SQ FT	SQUARE FOOT
FMF	FLOWMETER FITTING	SS	STAINLESS STEEL
FO	FUEL OIL	SSUL	SODIUM SULFITE
FOF	FUEL OIL FILL	STR	STORM DRAIN
FOO	FUEL OIL OVERFLOW	SW	SOFT WATER
FOR	FUEL OIL RETURN	TS	TAMPER SWITCH
FOS	FUEL OIL SUPPLY	TSP	TOTAL STATIC PRESSURE
FOSUCT	FUEL OIL SUCTION	TW	TREATED WATER
FOT	FUEL OIL TRANSFER	TWR	TEMPERED WATER RETURN
FOTP	FUEL OIL TRANSFER PUMP	TWS	TEMPERED WATER SUPPLY
FQV	FUEL OIL VENT	TYP	TYPICAL
FFM	FEET PER MINUTE	ΔT	TEMPERATURE DIFFERENCE
FPS	FEET PER SECOND	UCD	UNDERCUT DOOR
FS	FLOW SWITCH	UL	UNDERWRITERS LABORATORIES
FT	FOOT, FEET	V	VACUUM, VOLTS
FW	FEED WATER	VD	VOLUME DAMPER
FWR	FEED WATER RECIRCULATION	VENT	VENTILATION
FWS	FEED WATER SUCTION	VFD	VARIABLE FREQUENCY DRIVE
F	DEGREE(S) FAHRENHEIT	VSD	VARIABLE SPEED DRIVE
G	NATURAL GAS	VTR	VENT THROUGH ROOF
GAL	GALLON, GALLONS	W	WATTS, WIDE
GEN	GENERATOR	WB	WET BULB
GHR	GLYCOL HEATING RETURN	WC	WATER COLUMN
GHS	GLYCOL HEATING SUPPLY	WG	WATER GAUGE
GPH	GALLONS PER HOUR	WH	WALL HYDRANT
GPM	GALLONS PER MINUTE	WWF	WELDED WIRE FABRIC
GR	AUTOMOTIVE LUBRICATION PIPING	WWM	WELDED WIRE MESH

REVISIONS

REV	DESCRIPTION	DATE	APPROVED

CONSTRUCTION DOCUMENTS

THIS DRAWING AND ALL COPIES THEREOF IS THE PROPERTY OF RMF ENGINEERING, INC. THIS DRAWING MAY NOT BE USED OR REPRODUCED WITHIN ANY COMPUTER ENVIRONMENT OR BY ANY PRINT MEDIA FORMAT WITHOUT THE WRITTEN CONSENT OF RMF ENGINEERING, INC.

DRAWN BY: BMC DATE: 04/16/2022
 DESIGNED BY: BMC RMF JOB #: 220370-AD
 PROJ. MANAGER: CDC CLIENT PO#: P0106164
 SCO ID#: 21-22838-01-A 04/16/21

YANCEYVILLE CENTER RENOVATION

FIRE PROTECTION SYMBOLS, LEGEND & ABBREVIATIONS

rmf ENGINEERING, INC.
 8720 RED OAK BLVD, SUITE 370
 CHARLOTTE, NC 28217
 P: 704.909.6612
 NC LICENSE No: C-1125
 JOB No. 20370-AO

FP001